### CM1910-W UNITY<sup>™</sup> SLOT 3" Dual Overbed Units

Project:

### VisaLighting.com/Families/Unity

**VISA LIGHTING** 


Location:




#### Set includes 2 units in tandem. Order one model number per set

#### DIMENSIONS

Type:






#### FEATURES

- Integral drivers
- Optional 90+ CRI
- Dimming/switching interface accessory available for pillow speaker/nurse call systems
- Left and right models wired discretely; units may be wired together in the field
- Chicago Plenum certified
- Recessed depth minimizes interference with systems within ceiling plenum
- Formed acrylic lenses
- Snap-in acrylic lens for tool-less access
- Antimicrobial finishes (no VOC) on all interior and exterior painted surfaces
- ETL listed for damp locations. Not suited for exterior applications

#### PHOTOMETRICS



## CM1910-W UNITY SLOT (cont.) 3" Dual Overbed Units

## VISA LIGHTING

Sold Only as a Dual Overbed Set (Set includes two units in tandem)

Fill in shaded boxes using information listed below CM1910-W SOURCE<sup>1</sup> **SOURCE OPTION**<sup>2</sup> DIMMING CONTROL<sup>4</sup> MOUNTING<sup>5</sup> MODEL VOLTAGE<sup>3</sup> FINISH L30K 90CRI 347V OPTION (for FLGD option) FLGD (select finish) L35K MVOLT DALI SBAR See last page Minimum 80CRI is L40K TBAR for finish standard if option order codes is not selected VOLTAGE<sup>3</sup> (Select one) SOURCE<sup>1</sup> (Select one) Dimmable 0-10V to 1%, Minimum 80CRI, within 3-step MacAdam MVOLT 120-277V, 50/60 Hz **Delivered Lumens** 347V 347V, 50/60 Hz Source Ambient Exam Combined L30K 5300 7600 12700 L35K 5400 7800 13100 L40K 5600 8000 13400 Power (Watts) 57 89 144

Note: Fixture provided with separate ambient and exam circuits

#### SOURCE OPTION<sup>2</sup>

80 CRI within 3-step MacAdam is standard if option is not selected

**90CRI** Color rendering index minimum 90, minimum R9 value of 50 (delivered lumens reduced by 5%)

#### **DIMMING CONTROL OPTION<sup>4</sup>**

A Option availability may be interdependent with Voltage, Source or Other Options Dimmable to 1% if no dimming option is selected

DALIControl via DALI protocol, dimming to minimum 1% (not available with 347V)

#### MOUNTING<sup>5</sup> (Select one)

FLGD	Flanged drywall ceiling (Select finish color)								
SBAR	Screw-slot lay-in t-grid ceiling								
TBAR	9/16" and 15/16" standard lay-in t-grid ceiling								

#### ACCESSORY (Order separately)

LVPC-DIM	Low voltage patient control interface (3 load with dimming) requires minimum of one switch
	per zone (by others), mounts in electrical box (by others). Not compatible with -DALI option

# CM1910-W UNITY SLOT (cont.) 3" Dual Overbed Units



#### UNITY SLOT PRODUCT FAMILY

	• CB1911-T — 3" Tunable Slot Sconce							
Wall Units	• CB1911-W — 3" Slot Sconce							
	• CM1910-W — 3" Tandem Overbed Units							
Ceiling	• CM1910-T — 3" Tunable Tandem Overbed Units							
Mount Units	• CM1911-W — 3" Single Slot Ceiling Unit							
	• CM1911-T — 3" Tunable Slot Ceiling Unit							

See Visalighting.com/families/Unity-Healthcare-Lighting for more information

#### FINISHES

Specify color code when ordering. For accurate color matching, individual paint and finish samples are <u>available upon request</u>. For more information about our finishes visit <u>visalighting.com/finishes</u>

#### Powder Coat Paint Finishes (Standard)

AGGY	Agate Grey	ALGN	Alpine Green	BMAT	Bronze Matte	BRNZ	Bronze	BSIL	Blade Silver	CVBL	Cove Blue	DEOR	Deoro Gold
GLWT	Glacier White	GSIL	Graphite Siver	HRGR	Harbor Grey	JTBK	Jet Black	OCBL	Ocean Blue	SHGR	Shoreline Grey	SBGN	Sagebrush Green
SLGR	Slate Grey	SSTP	Sierra Taupe	TRCN	Terracotta Canyon	TRWT	Traffic White	VBLK	Velvet Black	VNRD	Vineyard Red	- -	

This document contains information which is the property of Visa Lighting, and may not, in whole or in part, be duplicated, disclosed, or used for design or manufacturing purposes without the prior written permission of Visa Lighting. ©Visa Lighting. Design Modification Rights Reserved. Visa Lighting reserves the right to change specifications for product improvement without notification.

Rev: 2025/03/18